SSO, Event Details Page 1 of 3



Event Search

Overflow / Bypass Event Details

Initial Report

Facility Name: Bolivar WWTF
Permit No: MO0022373

Once you enter the Event End Date & Time fields and Add Event/Save Changes, you will no longer be able t

1		
	Event Details	
	Bypass = at the wastewater treatment plant; Overflow = in the collect	
	Confirmation No: 147	9
	*Type of Event: By	pass
	*Wet or Dry Event? We	et 🔽
	*Event Begin Date: 12/0	04/2012 (MM/DD/YYYY)
	*Event Begin Time: 02:0	(HH:MM) Military Time
	**Event End Date: 12/0	04/2012 (MM/DD/YYYY)
	**Event End Time: 07:0	(HH:MM) Military Time
	Event Duration (hh:mm) 0d:5	5h:0m:
	*Initial Report Date: 12/0	04/2012 (MM/DD/YYYY)
	*Initial Report Time: 07:3	(HH:MM) Military Time
	Discharged To: Wa	nterway
	*Reported By: Joe	Cornell
	*Immediate Contact(41	7) 328 - 0271
	Ongoing?:	
	*Estimated Volume at time of Initial Report (gallons): 100	0.00
	Is bypass/overflow reaching Waters of the State?	
	Effected Waterbody: tow	nbranch
	**Cause of Event: Ra	in 🔽
	Cause of Event Comments:	

^{*} Indicates a Required Field

^{**}Indicates a Required Field for Final Report

SSO, Event Details Page 2 of 3

	Plant became hydraucally overloaded	
Event Type:	* To color more than one chains hold down the control key o	
Additional Impact:	* To select more than one choice hold down the control key o	
·	Public Beach or Public Use Area Impacted Dry Weather Release	
	Drinking Water Intakes Affected Release Volume Greater Than 50,000 Gal	
	Wet Event Details	
*Wet Event Start Date:		
**Wet Event End Date:	12/04/2012 (MM/DD/YYYY)	
*Precipitation Type:	Rain 🔽	
**Precipitation Amount (inches):	1.57	
*Soil Conditions:	saturated	
	Location Information	
County		
UTM Easting:		
UTM Northing:	4162368.266	
* Location Description	1801 E Broadway	
Double click on the map to zoom in. The mouse wheel or the slider may be used to zoom in or out. Use the pan buttons o		
to another location. Select a county from the drop down to zoom to that county.		
County: Polk		
Scale 1:2,400		
Flag Icon Select the red indicator to activate the marking tool then single click on the map to mark the location of you		

SSO, Event Details Page 3 of 3



5 - Day Report

**Estimated Final Total Volume (gallons): 698000.00

Did bypass reach Waters of the State?

**Response: Test results will follow



1-800-361-4827 / 573-751-1300 E-mail: cleanwater@dnr.mo.gov